


Encl-4



कार्यालय नगर निगम, देहरादून।



(का०- 0135-2714074:फैक्स- 0135-2651060: ई-मेल- (nagarnigam.ddn@gmail.com)

पत्रांक:- 6913 (4)

दिनांक:- 27/4/22

प्रमाण-पत्र

प्रमाणित किया जाता है, कि "श्री गुरु राम राय पब्लिक स्कूल" स्थित-रेसकोर्स, देहरादून में पीने के पानी एवं शौचालय/मूत्रालय का सफाई सम्बन्धित निरीक्षण क्षेत्रीय सफाई निरीक्षक द्वारा दिनांक 22-04-2022 को किया गया। स्कूल में सफाई व्यवस्था सही पायी गयी। सफाई सम्बन्धित कोई आपत्ति नहीं है तथा सफाई सम्बन्धित अनापत्ति प्रमाण पत्र जारी किया जाता है, जिसकी वैधता 31 मार्च, 2023 तक होगी।

मुख्य नगर स्वास्थ्य अधिकारी,
नगर निगम, देहरादून।



State Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun
Ph (O): 0135-2746137, E-mail: eenorth-ujs-uk@nic.in



TC-5372

URL No.: TC5372180000000874F

Test Report ID: 1193/UJS/SLWQTML/2021-22

Dated: 07/03/2022

TEST REPORT

Name and Address of Organization/ Customer	Shri Guru Ram Rai Public School, Race Course, Dehradun.		
Product Description (Surface Water/ Ground Water/ Drinking Water)	Drinking Water	Sample Description	One Water Sample collected from Shri Guru Ram Rai Public School
Reference Sample Identification:	SLWQTML/UJS/SGRR-01		Date of Start of Analysis: 03/03/2022
			Date of End of Analysis: 06/03/2022
Date and Time of Sample Received: 03/03/22&12:15AM	Sample Collected by:	Customer	

S N	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	pH at 25 ⁰ C	7.79	6.5 to 8.5	No Relaxation	IS 3025 (Part 11) 1983, RA: 2017: Electrometric method
2.	Total Dissolved Solids (TDS), mg/L, Max	64	500	2000	IS 3025 (Part 16), 1984 RA: 2017: Gravimetric Method
3.	Turbidity, NTU, Max	Less than 01	1	5	IS 3025 (Part 10), 1984, RA:2017: Nephelometric Method
4.	Total Alkalinity (as CaCO ₃), mg/L, Max	38	200	600	IS 3025 (Part 23), 1986 RA: 2019 Titrimetric Method
5.	Total Hardness (as CaCO ₃), mg/L, Max	42	200	600	IS 3025 (Part 21), 2009 RA:2019, (a) EDTA Titrimetric Method
6.	Fluoride, mg/L, Max	Less than 0.2	1.0	1.5	APHA 23rd Ed. 4500-F-D: 2017: SPADNS Method
7.	Nitrate, mg/L, Max	Less than 01	45	No Relaxation	APHA 23rdEd. 4500-NO ₃ -B:2017: Ultraviolet Spectrophotometric Screening Method
8.	Sulfate, mg/L, Max	09	200	400	APHA 23rd Ed. 4500-SO ₄ ⁻ E:2017:Turbidimetric Method

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.

Vikash Khandari
07/03/22
Technical Manager
(Dr. Vikash Khandari)
SLWQTM, LAB
Uttarakhand Jal Sansthan
Dehradun

-End of Report-

- The results listed refer only to tested sample and applicable parameters.
- This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
- The samples will be destroyed after fifteen days from the date of issue of test certificate. unless otherwise agreed with customer.



State Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun
Ph (O): 0135-2746137, E-mail: eenorth-ujs-uk@nic.in

Test Report ID: 1194/UJS/SLWQTML/2021-22

Dated: 07/03/2022

TEST REPORT

Name and Address of Organization/ Customer	Shri Guru Ram Rai Public School, Race Course, Dehradun.		
Product Description (Surface Water/ Ground Water/ Drinking Water)	Drinking Water	Sample Description	One Water Sample collected from Shri Guru Ram Rai Public School
Reference Sample Identification:	SLWQTML/UJS/SGRR-01		Date of Start of Analysis: 03/03/2022
Date and Time of Sample Received: 03/03/22&12:15AM	Sample Collected by:	Customer	
			Date of End of Analysis: 06/03/2022

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	Chloride, mg/L, <i>Max</i>	2.9	250	1000	IS 3025 (Part 32): 1988, RA: 2019 Argentometric Method
2.	Residual Free Chlorine, mg/L, <i>Min</i>	Less than 0.2	0.2	1.0	APHA 23rd Ed.-4500-Cl-G
3.	Colour, Hazen, <i>Max</i>	Less than 05	5	15	IS 3025 (Part 4): 2021 Platinum Cobalt (Visual Comparison)
4.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8) : 1984, RA:2017
5.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5) : 2018
Bacteriological Parameters					
6.	Total Coliform, MPN/ 100ml	Absent	Absent	Absent	APHA 23rd Ed.-9223-B
7.	<i>E. coli</i> , MPN/ 100ml	Absent	Absent	Absent	APHA 23rd Ed.-9223-B

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.

Vikash Kandari
07/03/22

(Dr. Vikash Kandari)
Technical Manager
SLWQTM, LAB
Uttarakhand Jal Sansthan
Dehradun

-End of Report-

- The results listed refer only to tested sample and applicable parameters.
- This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
- The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.